

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20182604  
Address: 837 NW DONOVAN RD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Rough Framing Inspection - Commercial</b>	John Borns	Failed	Monday, November 04, 2019

Partial Correction:  
1 Misc      INSTALLATION OF ROOF SHEATHING:  
LEFT WING: SUBSTANTIALLY COMPLETED -- SOME OVER-DRIVEN LOCATIONS TO BE RE-NAILED;

Partial Correction:  
2 Misc      SHEAR WALLS AT BOTH ENDS OF BLDG A: **RE-NAIL TO ACHIEVE OR EXCEED SPECIFIED 6"/12" FLUSH NAILING**

**Comments:**