

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20192822
Address: 4068 NE CHAPEL MANOR DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Plumbing Inspection - Residential	Khanh Nguyen	Partial	Monday, November 04, 2019

Corrective Action Required:

1	Misc	-ADD SUPPORT STRAPS FOR PLUMBING. CAN CHECK LATER AT FLOOR INSPECTION
---	------	---

Comments: