

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20192786
Address: 1006 SW BLUE PKWY, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|--|------------|----------|---------------------------|
| Occupancy Inspection - Codes Commercial | John Borns | Failed | Monday, November 04, 2019 |

Corrective Action Required:

| | | |
|---|------|---|
| 1 | Misc | NEC 380-10; 410-56(f) / IRC E3901.10; E3902.6 SECURING OF ELECTRICAL RECEPTACLES / SWITCHES: SECURE ONE LOOSE AT RECEPTION AREA SOUTH |
|---|------|---|

Corrective Action Required:

| | | |
|---|------|--|
| 2 | Misc | FURNACE/WATER HEATER VENT PIPE IS OPEN AT FITTING. FAS SUPPLY TO BE SHUT OFF UNTIL APPROVED. |
|---|------|--|

Corrective Action Required:

| | | |
|---|------|--|
| 3 | Misc | NEC 408.4 ELECTRICAL SERVICE PANEL SCHEDULE: ENSURE ALL CIRCUIT POSITIONS ARE PROPERLY LABELED. MUST BE LEGIBLE, COMPLETE, CURRENT, SPECIFIC. NO DITTO MARKS OR CONTINUATION SYMBOLS EXCEPT @ MULTIPLE POLE BREAKERS. LABEL UNUSED BREAKERS "SPARE". |
|---|------|--|

Corrective Action Required:

| | | |
|---|------|--|
| 4 | Misc | IPC 420.3: WATER CLOSET SEAT(S) MUST BE COMMERCIAL TYPE WITH OPEN FRONT. |
|---|------|--|

Corrective Action Required:

| | | |
|---|------|--|
| 5 | Misc | LS CODE OF ORDINANCES 17-309: DISPLAY OF "NO SMOKING" SIGN(S) REQUIRED AT PUBLIC ENTRY(IES). SHALL BE CONSPICUOUS AT EACH PUBLIC POINT OF ENTRY. |
|---|------|--|

Corrective Action Required:

| | | |
|---|------|--|
| 6 | Misc | OCCUPANCY STATUS: OK TO SET UP FOR BUSINESS. STAFFING, TRAINING, FIXTURING, STOCKING OK. NO PUBLIC/CUSTOMERS/PATIENTS PRIOR TO APPROVAL. |
|---|------|--|

Comments: