

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20191770  
Address: 2861 NE INDEPENDENCE AVE, Unit:101, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Rated Assembly Inspection</b>	Khanh Nguyen	Partial	Monday, November 04, 2019

Partial Correction:

1 Misc

2-HR FIRE BARRIER:

-ELECTRICAL RM-2ND LAYER OK

-SPRINKLER RM-1ST LAYER OK

-COLUMN G WALL: 1ST LAYER OK; COLUMNS-2ND LAYER OK

-WALL LINE 7 FROM H.8 TO J.5-2ND LAYER OK WITHIN SOFFIT, 1ST LAYER OK BELOW SOFFIT

1-HR WALL:

-ROW 2.2 WALL ROCKED ON 1 SIDE IN RM 1171-1173-OK

**Comments:**