

DEVELOPMENT SERVICES

Building Permit - Residential Project Title: Work Desc: NEW SINGLE FAMILY	Permit No: PRRES20193102 Date Issued: November 04, 2019
Project Address: 1824 SW MERRYMAN DR, LEES SUMMIT, MO 64082 Legal Description: THE MANOR AT STONEY CREEK 2ND PLAT LOTS 42-81 & TRACTS N-PLOT 59	Permit Holder: SUMMIT HOMES 120 SE 30TH ST LEES SUMMIT, MO 64082
Parcel No: 6970012030000000	
County: JACKSON	

Activities Included for this Project:

zNew Single Family, Right of Way, License Tax, License Tax Credit, Deck - Covered Residential,

Construction Type: Type VB	Occupancy: RESIDENTIAL, ONE- AND	Zoning District: R-1
(Unprotected)	TWO-FAMILY	
	Valuation: \$329,389.16	

Residential Area:	
Residential, Living Area	1030
Residential, Un-Finished basements	894
Residential, garage	638
Residential, Living Area 2	1242

Commercial Area	2272 sq. ft.

Issued By:KB	Date: Nov 04, 2019

THIS PERMIT IS ISSUED IN RELIANCE UPON INFORMATION SUBMITED BY THE APPLICANT. THE BUILDING OFFICIAL MAY SUSPEND OR REVOKE WHENEVER THE PERMIT IS ISSUED IN ERROR, OR ON THE BASIS OF INCORRECT INFORMATION SUPPLIED, OR IN VIOLATION OF ANY ADOPTED CODE, CITY ORDINANCE OR REGULATIONS.

NOTICE: THE DISPOSAL OF DEMOLITION WASTE IS REGULATED BY THE DEPARTMENT OF NATURAL RESOURCES UNDER CHAPTER 260 RSMO. SUCH WASTE, IN TYPES AND QUANTITIES ESTABLISHED BY THE DEPARTMENT, SHALL BE TAKEN TO A DEMOLITION LANDFILL OR A SANITARY LANDFILL FOR DISPOSAL.

CONDITIONS

One or more divisions have conditions that have not been addressed during the review period. The outstanding conditions provided below shall be met as indicated during the construction period.

Plot Plan Review

Residential Plan Review

220 SE Green Street | Lee's Summit, MO 64063 |816.969.1200 | 816.969.1201 Fax | cityofLS.net/Development

1 Designate locations of smoke detectors and carbon monoxide detectors. (IRC Section R314 and R315) No smoke detector shown on the main level

Signature of	
Applicant:	Date:NOVEMBER 4, 2019
Print name:	Company Name:_SUMMIT HOMES