

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20192146
Address: 2516 SW RIVER TRAIL RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Brandon Kalwei	Failed	Wednesday, November 06, 2019

Corrective Action Required:

- | | | |
|---|------|---|
| 1 | Misc | <ul style="list-style-type: none">- Loose hold down nuts in garage and basement throughout- fire block heat chase at top plate in garage, around piping- fire block waterline penetration in air return on first level half bathroom- insulate cantilever in main area before covering- clothes dryer vent wall needs to be firmed out or 2x6 framed wall. Vent cannot be contorted- ufer ground bonding wire is loose at connection- cantilevered section at rear of house not complete, covered |
|---|------|---|

Ok to insulate

Comments: