

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20191998
Address: 1321 NE GOSHEN DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mark Harding	Failed	Thursday, November 07, 2019

Corrective Action Required:

1 Misc

FRAMING:

-Fb garage wall space from fur-down ceiling space.

-Verification of deck roof beam support, support ridge as a beam or install rafter ties in lower 1/3 of rafters.

-Support ridge above foyer to lvl rafter

Comments: