

SAB Construction
4 Car Charleston

Air Combustion Calculation			
Per IRC 2018 G2407.5.1			
Fuel Burning Appliance #1	Furnace	200000	Btu/h
Fuel Burning Appliance #2		100000	Btu/h
Fuel Burning Appliance #3		NA	Btu/h
Total Btu/h		300000	Btu/h
Area of useable space		1450	sq.ft
Ceiling height in useable space (no sheetrock)		9	ft
Volumne of space		13050	
Required Volume of Air = total Btu/h * (50 cu.ft./1000 Btu/h)		15000	cu.ft.
Required Area of Usable Space		1666	sq.ft.
Standard Method of Work?		BAD	
Combustion Air Transfer Grille			
Per IRC G2407.5.3.1			
Required Opening Free Space = 1 sq.in./1000 Btu/h			
	=	160	sq.in.
Size of grille to be used	=	(2) 14"x8"	
Note: If fuel burning appliances are enclosed, (1) opening is required within 12" of floor and (1) opening is required within 12" of top enclosure			

SAB Construction