

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20191733  
Address: 1313 NE GOSHEN DR, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Khanh Nguyen	Partial	Friday, November 08, 2019

Corrective Action Required:

1 Misc

FRAMING:

-Have engineer address non-continuous studs at rear living room wall and joist bored within 2" of joist bottom by furnace pipes  
\*\*Support the joist per engineer letter item 3

\*\*OK TO ROCK

Comments: