

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20191536
Address: 1109 NE GOSHEN CT, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Khanh Nguyen	Failed	Friday, November 08, 2019

Corrective Action Required:

1	Misc	-Fb duct chase from joist space
		-Install number of stud support for I beam (beam between living rm and foyer/front dining) per plan
		**I don't remember how many studs are shown on the plan. There should be min 3 studs at end of the I beam
		-Provide full stud support under double joist at 1st fl bedroom

Comments: