

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20191010
Address: 4011 SW MERITAGE LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Driveway Inspection	Ronald Paynter	Failed	Friday, November 08, 2019

Corrective Action Required:

1	Misc	Forms were placed and aggregate was present. Cross slope of driveway approach is out of tolerance of ADA specs. RP 11-8-19
---	------	--

Informational:

2	Misc	After further investigation, lot 4011 does NOT have a sidewalk. The driveway approach is GOOD to pour as is. RP 11-8-19
---	------	---

Comments: