

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20191010  
Address: 4011 SW MERITAGE LN, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Driveway Inspection</b>	Ronald Paynter	Partial	Friday, November 08, 2019

Corrective Action Required:

1	Misc	Forms were placed and aggregate was present. Cross slope of driveway approach is out of tolerance of ADA specs. RP 11-8-19
---	------	--

Informational:

2	Misc	After further investigation, lot 4011 does NOT have a sidewalk. The driveway approach is GOOD to pour as is. RP 11-8-19
---	------	---

**Comments:**