

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20191576  
Address: 1808 SW MERRYMAN DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Brandon Kalwei	Failed	Friday, November 08, 2019

Corrective Action Required:

1 Misc

PLUMBING:

-Protect plumbing at kitchen duct chase  
-Gas line to fireplace located outside basement ceiling joist space. Redo gas line to fireplace and retest. Do not notch joist.

**\*\*OK TO INSULATE**

**Comments:**