

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20190489
Address: 4422 SW AMETHYST DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Brandon Kalwei	Failed	Friday, November 08, 2019

Corrective Action Required:

1	Misc	<ul style="list-style-type: none">- Seal outside light fixtures, penetrations, etc- hammer arrestor needed for dishwasher- handrail needed for first set of steps going up to second level- discharge pipe for hot water heater is too close to floor, needs to be code compliant with distance- anti siphon device screw in basement needs to be installed properly- final grade, sod, splash blocks needed
---	------	---

Comments: