

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20190228  
Address: 2622 SW RIVER TRAIL RD, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Brandon Kalwei	Failed	Friday, November 08, 2019

Corrective Action Required:

1	Misc	-need to verify that hammer arrestors are installed for the clothes washer - sump pump discharge needs to be cut back to code  ** sump pump still not cut back to code, cannot verify if hammer arrestors are installed
---	------	--

**Comments:**