

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRRES20191496  
Address: 1800 SW MERRYMAN DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Brandon Kalwei	Failed	Monday, November 11, 2019

Corrective Action Required:

- |   |      |  |
|---|------|--|
| 1 | Misc | <ul style="list-style-type: none"><li>- Secure gas line for fire place</li><li>- fire block penetrations at top and bottom plate mechanical and plumbing bump out in living room and hole cut in subfloor</li><li>- install steel post in garage</li><li>- over notched studs at front garage portal where bolts and washer installed</li><li>-install correct dryer box for clothes dryer vent so that vent is not contorted From original shape</li><li>- joist hangers needed on east side of basement</li><li>- anchor posts in basement</li></ul> |
|---|------|--|

Ok to insulate

**Comments:**