

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20191580
Address: 1503 SW ARBOR FALLS DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Brandon Kalwei	Failed	Monday, November 11, 2019

Corrective Action Required:

1	Misc	-loose hold down nuts throughout garage - fire stop at top plate double wall where piping goes through in garage. South side of garage - fire block dead space on living room. SW corner - secure gas fireplace gas line - double joist hangers needed in between living room and kitchen - clothes dryer vent cannot be in 2x4 stud wall - fire block double wall at top plate, west side stair landing going to basement
---	------	---

Ok to insulate

Comments: