



PLANS REVIEW CONDITIONS

Permit No:	PRCOM20191001	Date:	November 11, 2019
Project Title:	HT SOLUTIONS - ADDITION	Applicant:	
Location:			
1440 SE BROADWAY DR, LEES SUMMIT, MO 64081		ELECTRONIC CONTRACTING COMPANY	
Type of Work:		6501 NORTH 70TH ST	
Occupancy Group:	F-2	LINCOLN, NE 68504	
Description:	ADDITION TO EXISTING FACTORY		
Construction Type:	Type IIB (Unprotected)	Primary:	(402) 466-8274 Ext: MAILING
Map Page:	195R		

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Alarm Plan Review

Reviewed By: Michael Weissenbach

Released for Construction

1. 2018 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.
(Information Purposes)
Call (816)969-1300 to schedule alarm testing

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.