

**PLANS REVIEW CONDITIONS**

Permit No:	PRCOM20192339	Date:	November 11, 2019
Project Title:	SANO ORTHOPEDICS	Applicant:	
Location:	2861 NE INDEPENDENCE AVE, Unit:201, LEES SUMMIT, MO 64064	JAYHAWK FIRE SPRINKLER CO INC 12030 S HEDGE LANE TERRACE OLATHE, KS 66061	
Type of Work:			
Occupancy Group:	B	Primary:	(913) 422-3770
Description:	TENANT FINISH FOR MEDICAL OFFICE		
Construction Type:	Type IIB (Unprotected)		
Map Page:	175R		

**Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.**

**Sprinkler Plan Review**

**Reviewed By: Michael Weissenbach**

**Released for Construction**

1. 2018 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

(Action Required)

Call (816)969-1300 to schedule a Hydrostatic Test.

**The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.**