

PLANS REVIEW CONDITIONS

Permit No:	PRCOM20190138	Date:	November 13, 2019
Project Title:	MID-CONTINENT PUBLIC LIBRARY EAST	Applicant:	
Location:			
2240 SE BLUE PKWY, LEES SUMMIT, MO 64063	PROGRESSIVE ELECTRONICS INC		
Type of Work:		6102 ARLINGTON AVE	
Occupancy Group:	A-3	RAYTOWN, MO 64133	
Description:	NEW PUBLIC LIBRARY		
Construction Type:	Type IIB (Unprotected)	Primary: (816) 765-5750	
Map Page:	196K		

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Alarm Plan Review

Reviewed By: Michael Weissenbach

Released for Construction

1. 2018 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

(Informational Purposes)

Call (816)969-1300 to schedule testing.

2. (Action Required)

Mount outside horn/strobe by FDC

Strobes only in Men's and Women's Restrooms

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.