

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20192761
Address: 4704 NE SARATOGA CT, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Foundation Inspection - Residential	Khanh Nguyen	Failed	Wednesday, November 13, 2019

Corrective Action Required:

1	Misc	-REBARS NOT INSTALLED PER PLAN. 10 FT WALL REQUIRES VERT. REBARS @ 8" OC. YOU HAVE WALL EXCEEDING THIS HEIGHT. GET THE ENGINEER INVOLVED
---	------	--

Comments: