

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20172517
Address: 233 NW KESSLER DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	Mark Harding	Partial	Wednesday, November 13, 2019

Corrective Action Required:

1	SECOND FLOOR	--SEAL ALL PRE ROCK AREAS FROM ATTIC. --INSTALL HURRICANE TIES AND TRUSS HANGERS. --PUDDY PADS NEED TO BE CORRECTED. --JOIST HANGER CEILING JOIST IN CORRIDOR --REMOVE BONDING SCREWS FROM NEUTRAL SIDE OF PANELS.
---	--------------	--

Corrective Action Required:

2	FIRST FLOOR
---	-------------

Corrective Action Required:

3	LOWER LEVEL
---	-------------

Comments: