



PLANS REVIEW CONDITIONS

Permit No:	PRCOM20192520	Date:	November 13, 2019
Project Title:	ARISTOCRAT PRE-OWNED AUTOMOTIVE DEALERSHIP	Applicant:	
Location:	704 SE OLDHAM CT, LEES SUMMIT, MO 64081	KELLER FIRE & SAFETY	
Type of Work:		1138 KANSAS AVE	
Occupancy Group:	B	KANSAS CITY, KS 66105	
Description:	NEW BUILDING FOR CAR DEALERSHIP WITH SINGLE CAR WASH BAY AND EQUIPMENT MEZZANINE	Primary: (913) 371-8494	
Construction Type:	Type IIB (Unprotected)		
Map Page:	195M		

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Alarm Plan Review

Reviewed By: Michael Weissenbach

Released for Construction

1. 2018 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

(Informational Purposes)

Call (816)969-1300 to schedule testing.

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.