

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRSITE20192650

Address: 855 NE WOODS CHAPEL RD, Unit:IR, LEES SUMMIT, MO 64064855 NE WOODS CHAPEL RD, LEES  
SUMMIT, MO 64064851 NE WOODS CHAPEL RD, Unit:IR, LEES SUMMIT, MO 64064851  
NE WOODS CHAPEL RD, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:              | Inspector:   | Outcome: | Date:                       |
|--------------------------|--------------|----------|-----------------------------|
| <b>DE - Storm - Pipe</b> | John Jackson | Partial  | Thursday, November 14, 2019 |

Informational:

1 Misc

Contractor ( Bair Excavation) installed approximately 70' of 18" HDPE storm pipe. 0+00 to 70+00. Gravel was layed to ensure storm pipe meets grade with a 0.75% slope.

**Comments:**