

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20190274

Address: 2861 NE INDEPENDENCE AVE, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Rated Assembly Inspection</b>	Khanh Nguyen	Partial	Thursday, November 14, 2019

Corrective Action Required:

1 Misc

2-HR FIRE BARRIER WALL:

-WALL FROM H.8/7 TO J.5/7-1ST LAYER OK

-WALL IN ELECTRICAL RM-2ND LAYER OK

ELEVATOR SHAFT WALL: 1" GYP BOARD INSTALLATION-OK

**Comments:**