

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSITE20192650

Address: 855 NE WOODS CHAPEL RD, Unit:IR, LEES SUMMIT, MO 64064855 NE WOODS CHAPEL RD, LEES SUMMIT, MO 64064851 NE WOODS CHAPEL RD, Unit:IR, LEES SUMMIT, MO 64064851 NE WOODS CHAPEL RD, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
DE - Storm - Pipe	John Jackson	Partial	Thursday, November 14, 2019

Informational:

1

Contractor poured poured flowable fill over all storm pipe that was layed in parking lot stalls and driveing areas as per plan. Cotractor proposed plan to mix black color to 8" of concrete til it met existing parking lot grade (this plan was approved). At this time the contractor has decided to return to the original Asphaltic Concrete Street Repair See C 11.0. 11/13/19

Comments: