

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20191408

Address: 2101 NE INDEPENDENCE AVE, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	Khanh Nguyen	Failed	Friday, November 15, 2019

Partial Correction:

1 Misc

ABOVE-CEILING OK:

-TWO OFFICES-OK TO MOVE ITEMS IN WHILE WORK CONTINUE IN SHOW ROOM

-RM 103-106 INSPECTED. REMOVE NON-PLENUM RATED CABLE FROM ABOVE-CEILING PLENUM SPACE; WRAP EXPOSED ROOF DRAIN PVC PIPES LOCATED IN PLENUM SPACE WITH APPROVED LISTED MATERIAL

Comments: