

City of Lee's Summit
Development Services
220 SE Green Street
Lee's Summit, MO 64063

Plumbing Inspector

Re: Taco Bell – 851 NE Woods Chapel Rd. Lee's Summit MO

Regarding the size of the grease waste line for the Taco Bell on Woods Chapel Rd. The Taco Bell prototype typically requires a 6" diameter grease line for their own purposes to reduce clogging. Due to a conflict between the civil drawings and the plumbing drawings, the grease waste piping was installed as 4" diameter.

The total drainage fixture units for the grease line are only 34 DFU, which is well under the limit of 180 DFU for a 4".

The building owner has approved the change to 4", and I find it acceptable as well.

Please feel free to contact me with any questions.



Brian Quissell P.E.
BC Engineers Inc.