

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20191809  
Address: 851 NE WOODS CHAPEL RD, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>In-wall Inspection</b>	Khanh Nguyen	Partial	Friday, November 15, 2019

Corrective Action Required:

1	Misc	-ANCHOR THE KITCHEN HOOD WALL BOTTOM TRACK. FASTEN THE SHEATHING TO BOTTOM TRACK -PROTECT PLUMBING WHERE WITHIN 1.25" OF THE WALL PLATES SURFACE -FIRE BLOCK WALL FROM ROOF SPACE
---	------	---

**Comments:**