CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #:	PRCOM20192047
Address:	300 SW BLUE PKWY, Unit:B, LEES SUMMIT, MO 64063
Inspected On:	Friday, November 15, 2019
Inspected By:	John Borns
Expiration Date:	11/21/2019

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	John Borns	Temporary C of O	Friday, November 15, 2019

Corrective Action Required:

1 Misc ROOFTOP GAS PIPING: TWO REQUIRED SUPPORT BLOCKS LACK STRAPS TWO DIRT LEGS ARE NOT PAINTED

Corrective Action Required:

8 Misc JANITOR FLOOR SINK BEING CONSTRUCTED AT STOCK ROOM