

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20193135  
Address: 2920 NW AUDUBON Lane, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Footing Inspection - Residential</b>	Khanh Nguyen	Not Ready	Friday, November 15, 2019

Corrective Action Required:

1	Misc	NOT EVEN CLOSE TO BEING READY FOR INSPECTION. EROSION CONTROL NOT INSTALLED. INSPECTION DENIED. NOT-READY FEE ASSESSED
---	------	--

**Comments:**