

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20191386
Address: 2601 SW RIVER TRAIL RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Driveway Inspection	John DiMauro	Partial	Monday, November 18, 2019

Corrective Action Required:
1 Misc PRE POUR INSPECTION

The forms are set and there appears to be sufficient compacted aggregate.
The drive approach is formed over 36' ft and needs to be corrected to be less than 36' ft.

Comments: