

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSITE20191166
Address: 150 NW MURRAY RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
DE - Stabilized Subgrade	Ronald Paynter	Passed	Monday, November 18, 2019

Informational:
1 Misc Meet with JJ Martiny Concrete Construction. They are responsible for the sub grade stabilization and curbs. They are using Geo Grid and AB3 at 6 inches of depth. Because it is deemed a fire lane, they are cutting it down for 6 1/2 inches of asphalt. RP 11-4-19

Comments: