

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRSUBD20191897  
Address: 3200 SW PERGOLA PARK DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>DE - Water Line - Coliform Test 2</b>	Ronald Paynter	Passed	Monday, November 18, 2019

Informational: 1 Misc	Pulled second sample for Bac-T testing. RP 11-12-19
Informational: 2 Misc	Second Bac-t test passed. Notified Water, who will be turning on valves and flushing the loop. RP 11-13-19

**Comments:**