

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSITE20191166
Address: 150 NW MURRAY RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
DE - Storm - Pipe	Ronald Paynter	Passed	Monday, November 18, 2019

Informational:
1 Misc Marty's crew from Rainbow Construction has laid 337 feet of 15 inch HDPE storm pipe. They also set Nyloplast grate inlets A2, A3, A4 and A5. RP 7-20-19

Comments: