

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20190447
Address: 1801 SW MERRYMAN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Brandon Kalwei	Failed	Tuesday, November 19, 2019

Corrective Action Required:

- | | | |
|---|------|---|
| 1 | Misc | <ul style="list-style-type: none">- install erosion control at front of lot, clean up street and curb- Seal exterior light fixtures- anti-siphon set screw needs to be installed properly- hot water heater discharge pipe is too close to the finished floor, cut back to code- hole in downstairs bathroom ceiling needs to be fixed- hole in north basement bedroom ceiling needs to be fixed- low battery warning CO detector outside of front bedroom on 1st floor- sod, splash blocks, final grade |
|---|------|---|

Comments: