

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20191061  
Address: 1708 SW MERRYMAN DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Brandon Kalwei	Failed	Tuesday, November 19, 2019

Corrective Action Required:

1	Misc	<ul style="list-style-type: none"><li>- garage door needs to be self closing/latching</li><li>- no power running to garbage disposal</li><li>- kitchen counter top gfci not working properly</li><li>- both locking devices need to be installed for rear sliding door</li><li>- exterior light at back deck needs to be installed</li><li>- sump pump discharge needs to be installed to code</li><li>- sod, splash blocks, final grade</li></ul>
---	------	--

**Comments:**