

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Certificate of Occupancy

Permit #: PRCOM20192047
Address: 300 SW BLUE PKWY, Unit:B, LEES SUMMIT, MO 64063
Inspected On: Tuesday, November 19, 2019
Inspected By: John Borns

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection -	John Borns	Full C of O	Tuesday, November
Codes Commercial			19, 2019

Comments:

JANITOR FLOOR SINK AT STOCK ROOM TO BE GROUTED AND CAULKED.
PERMANENT PANEL SCHEDULES TO BE PUT IN PLACE AT THREE ELECTRICAL PANELS.
THRESHOLD OR TRANSITION STRIP TO BE INSTALLED WHERE TILE ENDS AT REAR CORRIDOR.