

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20191809  
Address: 851 NE WOODS CHAPEL RD, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Underground Electrical Inspection - Commercial</b>	Khanh Nguyen	Partial	Wednesday, November 20, 2019

Partial Correction:

1 Misc

OK TO COVER WHEN READY:

-TWO 60' RUNS OF 4" PVC CONDUIT FROM NE OF SE CORNER OF BLDG TO E OF  
NE CORNER OF BLDG;  
-WEST SIDE LOW VOLTAGE CONDUITS AND EXT. LIGHTS CONDUITS FROM SW  
CORNER TO ~40 FT NORTH OF BUILDING

**Comments:**