



### **PLANS REVIEW CONDITIONS**

Permit No:	PRCOM20191955	Date:	November 20, 2019
Project Title:	ATTIC STORAGE OF LEES SUMMIT	Applicant:	
Location:	920 NE DEERBROOK ST, LEES SUMMIT, MO 64086		
Type of Work:			AEGIS FIRE PROTECTION LLC
Occupancy Group:	S-1		11936 W 119TH ST
Description:	NEW ENCLOSED CONDITIONED		OVERLAND PARK, KS 66213
SELF STORAGE BUILDING		Primary:	(913) 825-0343
Construction Type:	Type IIB (Unprotected)		
Map Page:	175Z		

**Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.**

#### **Alarm Plan Review**

**Reviewed By: Michael Weissenbach**

**Released for Construction**

1. 2018 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

(Informational Purposes)

Call (816)969-1300 to schedule testing.

2. (Informational Purposes)

Mount outside Horn/Strobe by FDC

**The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.**