

Inspection Summary

Permit #: PRSUBD20181667, Development - Subdivision
Whispering Woods
Address: 2601 SW PRYOR RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
DE - Water Line - Coliform Test 1	John DiMauro	Failed	Thursday, November 21, 2019

Corrective Action Required

1 We collected the day 1 water samples for bacteria testing on Tuesday 11/19/19 and delivered them to Keystone Labs.

Test spot 2 of the samples failed for total coliforms.

We will now repeat the sampling process.

Comments: