

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20182959
Address: 1309 NE GOSHEN DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Khanh Nguyen	Failed	Wednesday, January 09, 2019

Corrective Action Required:

1	Misc	GARAGE PORTAL WALL ONLY: BLOCK AND NAIL AT SEAMS; STRAP INTERIOR SIDE PER CODE
---	------	--

Comments: