

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20182959
Address: 1309 NE GOSHEN DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Khanh Nguyen	Failed	Thursday, February 28, 2019

Corrective Action Required:

1	Misc	-Support end of triple 2x10 beam in front bathroom **Get your engineer to look at this -Frame and nail CSPF walls. See the plan detail **Straps not installed and siding not nailed per CSPF wall detail
---	------	---

Comments: