

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20182611
Address: 901 NW WARD RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	John Borns	Partial	Friday, November 22, 2019

Partial Correction:

1 Misc

OK TO COVER WHEN READY 5/8" MOLD-RESISTANT FIRECODE X GWB AT STAIRWELL WALLS INSIDE FACE AND SPACES BETWEEN JOISTS AT BACKSIDE:

EAST STAIRWELL:

BASEMENT LEVEL: **1ST LAYER;**

1ST FLOOR: **1ST LAYER AT JOIST SPACES ONLY;**

2ND FLOOR:

3RD FLOOR:

4TH FLOOR:

WEST STAIRWELL: **1ST LAYER AT JOIST SPACES ONLY;**

1ST FLOOR: **1ST LAYER AT JOIST SPACES ONLY;**

2ND FLOOR:

3RD FLOOR:

4TH FLOOR:

OK TO COVER WHEN READY 5/8" MOLD-RESISTANT FIRECODE X GWB AT ELEVATOR SHAFT WALLS AT:

BASEMENT LEVEL: **1ST LAYER AT JOIST SPACES ONLY;**
1ST FLOOR: **1ST LAYER AT JOIST SPACES ONLY;**
2ND FLOOR:
3RD FLOOR:
4TH FLOOR:

Comments: