



PLAN REVIEW CONDITIONS

November 22, 2019

INDUSTRIAL AMERICAN CORP.
612 NE ENGLISH MANOR DR, Unit D
LEES SUMMIT, MO 64086

Permit No: PRCOM20193420
Project Title: KC COMFORT LLC
Project Address: 208 SE 3RD ST, LEES SUMMIT, MO 64063
Parcel Number: 61230150900000000
Location: HOWARDS W B 1ST ADD S 1/2 OF LOT 1 BLK 18
Type of Work: ALTERATION COMMERCIAL
Occupancy Group: BUSINESS
Description: REMOVING WALL TO ENLARGE AN EXISTING OFFICE
(WALL IS NOT LOAD BEARING AND HAS NO ELECTRICAL SO NO INSPECTIONS REQUIRED EXCEPT FINAL)

*drawing is in plan review file

The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please contact the appropriate department regarding clarification of comments.

Development Services Department (816) 969-1200

Fire Department (816) 969-1300

Building Plan Review

Reviewed By: Joe Frogge

Approved with Conditions

1. A License Tax application completed by the contractor must be submitted to the City of Lee's Summit, Codes Administration Department, and any applicable License Tax paid prior to issuing a building permit.

Action required: Comment is for informational purposes.

Fire Plan Review

Reviewed By: Michael Weissenbach

Approved with Conditions

1. 2018 IFC 505.1- Address numbers. New and existing buildings shall have approved address numbers, building numbers or approved building identification placed in a position that is plainly legible and visible from the street or road fronting the property. These numbers shall contrast with their background. In Multi-tenant commercial building where tenants have multiple entrances located on different sides of the building , each door shall be addressed. Address numbers shall be Arabic numerals or alphabet letters. Numbers shall be a minimum of 4 inches (102 mm) high with a minimum stroke width of 0.5 inch (12.7 mm).

(Verified At Inspection)

2. 2018 IFC 906.5- Conspicuous location. Portable fire extinguishers shall be located in conspicuous locations where they will be readily accessible and immediately available for use. These locations shall be along normal paths of travel, unless the fire code official determines that the hazard posed indicates the need for placement away from normal paths of travel.

(Verified At Inspection)

Provide one 2A10BC fire extinguisher

The approval of plans and specifications does not permit the violation of any section of the Building Codes or other City Ordinances or State Law.

The review conducted by the City of Lee's Summit Development Services Department shall not be construed as a structural review of the project.