

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20183200
Address: 1706 NW OBRIEN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	John Borns	Partial	Friday, November 22, 2019

Partial Correction:

1 Misc

OK TO COVER WHEN READY CEILING FRAMING + ABOVE-CEILING SYSTEMS
EXCEPT AT NORTH INTERCONNECT CORRIDOR AND EAST TRANSITION
CORRIDOR.

Comments: