

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20191809
Address: 851 NE WOODS CHAPEL RD, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection - Commercial	Khanh Nguyen	Failed	Friday, November 22, 2019

Corrective Action Required:

1	Misc	INSPECTION OF JUST THE UFER CONNECTION-VERIFY THAT THE CLAMP IS LISTED REBAR GROUNDING CLAMP TO BE BURIED IN CONCRETE. THE SCREWS&BOLT ARE NOT STAINLESS STEEL
---	------	----------------------------------------------------------------------------------------------------------------------------------------------------------------

Comments: