



PLANS REVIEW CONDITIONS

Permit No:	PRCOM20190683	Date:	November 22, 2019
Project Title:	THE GODDARD SCHOOL	Applicant:	
Location:			
3301 NE RALPH POWELL RD, LEES SUMMIT, MO 64064		ADVANTAGE FIRE PROTECTION SYSTEMS INC	
Type of Work:		404 B NW 11TH ST	
Occupancy Group:	E	BLUE SPRINGS, MO 64015	
Description:	NEW DAYCARE FACILITY		
Construction Type:	Type VB (Unprotected)	Primary:	(816) 224-3400
Map Page:	175M		

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Sprinkler Plan Review

Reviewed By: Michael Weissenbach

Released for Construction

1. 2018 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

(Informational Purposes)

Call (816)969-1300 to schedule a hydrostatic Test.

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.