

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20182733
Address: 2528 SW RIVER TRAIL RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Gas Service Inspection - Residential	Brandon Kalwei	Failed	Monday, November 25, 2019

Corrective Action Required:

1	Misc	Failed due to no access/lockbox combo
---	------	---------------------------------------

No erosion control at front of lot, needs to be installed before next inspection

Comments: