

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20191907
Address: 1901 NW LOWENSTEIN DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	John Borns	Failed	Monday, November 25, 2019

Corrective Action Required:

1	Misc	LSCO SEC 7-142; IBC 106: PERMIT DRAWINGS NOT FOUND ON SITE. NO INSPECTIONS WITHOUT CITY-STAMPED PERMIT PRINTS.
---	------	--

Corrective Action Required:

2	Misc	RIDGE BEAM IS NOT CONTINUOUS -- WITH NO SUPPORT AT BUTT JOINT.
---	------	--

Comments: